

Date: 20XX-XX

Høringsudgave 07.09.2026

DS/EN 1993-3:2026 DK NA:202X

**National Annex to: Eurocode 3 - Design of steel structures -
Part 3: Towers, masts and chimneys**

**Nationalt Anneks til: Eurocode 3 - Stålkonstruktioner -
Del 3: Tårne, master og skorstene**

Foreword

Published [måned og år].

This National Annex (NA) to EN 1993-3:2026 forms part of the Danish national annexes to the second generation of Eurocodes.

This NA supersedes DS/EN 1993-3-1 DK NA:2019 upon its implementation in the Building Regulations (Bygningsreglementet 2018 – BR18) as an appendix.

During the transition period stated in the Building Regulations, both the first generation and the second generation of the Eurocodes and NAs may be applied.

This NA cannot be used in conjunction with the first generation of Eurocodes.

This NA lays down the conditions for the Danish implementation of [DS/EN 1993-3:2026](#) for construction works in conformity with the Danish Building Regulations; Bygningsreglementet 2018 (BR18). Other parties may bring this NA into force by reference.

The Eurocodes establish the principle that certain parameters are left open for national determination. These parameters are referred to as *Nationally Determined Parameters* (NDP) and specifies the nationally applicable values, classes or methods. Furthermore, the NA may provide *Non-Contradictory, Complementary Information* (NCCI), i.e. additional guidance and alternative methods or values that support the application of the Eurocode without altering or contradicting its provisions.

Further, this National Annex includes NOTES. Notes have the status of guidance and provide additional information intended to assist the understanding or use of text of the national annex.

In conformity with the Danish Building regulations, the verbal forms used in this Eurocode and NA are to be understood as follows:

- “shall” expresses a requirement to be followed
- “should” expresses a recommendation. Alternative approaches could be used if technically justified
- “may” expresses permission within the limits of Danish Building Regulations
- “can” expresses a possibility or capability
- “is/are” expresses a statement of certainty or a fact

This NA includes:

- Foreword;
- An overview of clauses with possible Nationally Determined Parameters (NDPs) and of Non-Contradictory Complementary Information (NCCI);
- National choice to national Determined Parameters (NDP), and Non-Contradictory Complementary Information (NCCI)

Valid versions of the NAs as well as previous versions, addenda can be found at www.bygningsreglementet.dk.

Overview of possible Nationally Determined Parameters (NDPs) and Non-Contradictory Complementary Information (NCCI)

The list below identifies the clauses where Nationally Determined Parameters (NDPs) are possible, and whether a national choice has been made, and if an informative annex is applicable or not applicable. Furthermore, clauses providing complementary information (NCCI) are identified in the list below.

Clause	Subject	Nationally Determined Parameter	Non-Contradictory Complementary Information
4.1(4)	General rules	Unchanged	
4.2.3(2)	Other actions	Unchanged	
6.3.1(2)	Corrosion allowance for chimneys	Unchanged	
7.2(4)	Modelling of connections	Unchanged	
7.4(4)	Analysis of the structural shell	Unchanged	
8.1(1)	Ultimate limit states	National choice	
8.2.4.1(7)	Resistance verifications	Unchanged	
8.3.1(2)	Joints	Unchanged	
8.3.3(2)	Connection of the main structure to the foundation or supporting structure	Unchanged	
8.3.4.2(2)	Spherical pinned connection	Unchanged	
10.3(5)	Safety assessment	National choice	
B.3.2(3)	Metallic guys and tension elements	Unchanged	
B.3.3(3)	Non-metallic guys	Unchanged	
B.5.1(1)	Ladders, platforms, etc.	Unchanged	
B.5.2(3)	Lightning protection	Unchanged	
B.5.3(1)	Aircraft warning	Unchanged	
B.5.4(1)	Protection against vandalism	Unchanged	
C.3(3)	Buckling resistance of compression members	Unchanged	
C.5(8)	Leg members	Unchanged	
D.5(2)	Analysis after a guy rupture	Unchanged	
E.4(5)	Bolted connections	Unchanged	

Clause	Subject	Nationally Determined Parameter	Non-Contradictory Complementary Information
E.6.2.1(1)	Self-supporting structure	Unchanged	
E.6.2.2(3)	Guyed structures	Unchanged	
F.1(1)	Use of this Annex	Unchanged	
Annex F	Supplementary rules for the resistance of equal leg angle sections and built-up members	Informative	

NOTE

Unchanged: Recommendations in the Eurocode to be followed.

National choice: A National Determined Parameter is chosen and defined.

Complementary information: (Non-contradictory) complementary information on how to use the Eurocode.

Normative: The Annex shall be used.

Informative: The Annex may be used.

Not applicable: The Annex cannot be used.

No further information: The Eurocode allows further information. No further information is given.

National Determined Parameter (NDP) and Non-contradictory complementary Information (NCCI)

8.1(1) Ultimate limit states

(NDP)

The values of γ_{M0} , γ_{M1} and γ_{M2} shall be taken from EN 1993-1-1 8.1(1). The value of γ_{Mt} shall be 1,50 and the value of γ_{Mi} shall be 2,00.

10.3(5) Safety assessment

(NDP)

The values of γ_{Ff} shall be taken from EN 1990 8.3.3(1) and γ_{Mf} are given in EN 1993-1-9 5(6).